



Attachment 8B


			hr	lb/mmbtu	% Capacity	limit		
1	2018	7/2/2018	0	0.076	100.1%	0.1200	663.5	8729.7
1	2018	7/2/2018	1	0.078	99.8%	0.1200	678.3	8695.6
1	2018	7/2/2018	2	0.081	99.6%	0.1200	703.3	8682.9
1	2018	7/2/2018	3	0.08	99.9%	0.1200	696.7	8708.6
1	2018	7/2/2018	4	0.123	79.4%	0.1200	851	6918.4
1	2018	7/2/2018	5	0.343	50.7%	0.1200	1514.8	4416.4
1	2018	7/2/2018	6	0.352	50.3%	0.1200	1542.6	4382.3
1	2018	7/2/2018	7	0.361	51.3%	0.1200	1614.8	4473.1
1	2018	7/2/2018	8	0.377	51.9%	0.1200	1706.4	4526.1
1	2018	7/2/2018	9	0.377	51.9%	0.1200	1706.9	4527.6
1	2018	7/2/2018	10	0.374	52.1%	0.1200	1699.2	4543.2
1	2018	7/2/2018	11	0.366	51.7%	0.1200	1650.7	4510
1	2018	7/2/2018	12	0.36	51.6%	0.1200	1618.8	4496.7
1	2018	7/2/2018	13	0.36	56.3%	0.1200	1765.8	4905.1
1	2018	7/2/2018	14	0.261	76.7%	0.1200	1745	6686
1	2018	7/2/2018	15	0.072	89.4%	0.1200	561.2	7794.2
1	2018	7/2/2018	16	0.066	90.3%	0.1200	519.3	7868.1
1	2018	7/2/2018	17	0.076	89.9%	0.1200	595.5	7835.9
1	2018	7/2/2018	18	0.071	88.3%	0.1200	546.2	7692.8
1	2018	7/2/2018	19	0.07	87.7%	0.1200	534.9	7641.5
1	2018	7/2/2018	20	0.068	86.5%	0.1200	512.9	7542.2
1	2018	7/2/2018	21	0.084	86.6%	0.1200	634.2	7550.3
1	2018	7/2/2018	22	0.089	84.3%	0.1200	653.8	7346.6
1	2018	7/2/2018	23	0.079	79.8%	0.1200	549.4	6954.9




		hr	lb/mmbtu	% Capacity	limit			
1	2018	7/9/2018	0	0.296	45.9%	0.1200	1183.1	3996.9
1	2018	7/9/2018	1	0.303	45.7%	0.1200	1206.5	3981.7
1	2018	7/9/2018	2	0.3	45.9%	0.1200	1200.2	4000.6
1	2018	7/9/2018	3	0.311	45.9%	0.1200	1245	4003.1
1	2018	7/9/2018	4	0.306	45.4%	0.1200	1210.4	3955.4
1	2018	7/9/2018	5	0.306	45.2%	0.1200	1205.3	3939
1	2018	7/9/2018	6	0.305	45.0%	0.1200	1195.9	3920.8
1	2018	7/9/2018	7	0.306	45.0%	0.1200	1200	3921.7
1	2018	7/9/2018	8	0.303	45.6%	0.1200	1205.2	3977.5
1	2018	7/9/2018	9	0.308	45.4%	0.1200	1218.2	3955.3
1	2018	7/9/2018	10	0.312	45.7%	0.1200	1243.1	3984.4
1	2018	7/9/2018	11	0.316	45.5%	0.1200	1252	3961.9
1	2018	7/9/2018	12	0.316	45.8%	0.1200	1261.1	3990.9
1	2018	7/9/2018	13	0.322	45.7%	0.1200	1282.1	3981.8
1	2018	7/9/2018	14	0.33	45.3%	0.1200	1303.5	3950.2
1	2018	7/9/2018	15	0.324	45.4%	0.1200	1283.5	3961.3
1	2018	7/9/2018	16	0.324	45.3%	0.1200	1280	3950.7
1	2018	7/9/2018	17	0.308	45.1%	0.1200	1210.8	3931.3
1	2018	7/9/2018	18	0.31	45.2%	0.1200	1220.9	3938.3
1	2018	7/9/2018	19	0.311	50.3%	0.1200	1364	4386
1	2018	7/9/2018	20	0.308	63.0%	0.1200	1690.7	5489.2
1	2018	7/9/2018	21	0.313	63.0%	0.1200	1718.1	5489.1
1	2018	7/9/2018	22	0.318	63.2%	0.1200	1750.7	5505.2
1	2018	7/9/2018	23	0.319	63.0%	0.1200	1751.6	5491
1	2018	7/10/2018	24	0.321	63.0%	0.1200	1763.4	5493.5
1	2018	7/10/2018	25	0.317	63.0%	0.1200	1741.7	5494.3
1	2018	7/10/2018	26	0.321	63.1%	0.1200	1765.6	5500.3
1	2018	7/10/2018	27	0.328	63.3%	0.1200	1810.9	5521.1
1	2018	7/10/2018	28	0.332	63.5%	0.1200	1839.1	5539.6
1	2018	7/10/2018	29	0.207	76.4%	0.1200	1378.3	6658.4
1	2018	7/10/2018	30	0.074	79.2%	0.1200	510.9	6904.5
1	2018	7/10/2018	31	0.07	79.5%	0.1200	485.1	6930.6
1	2018	7/10/2018	32	0.076	79.2%	0.1200	524.9	6906.7
1	2018	7/10/2018	33	0.068	79.7%	0.1200	472.3	6945.1
1	2018	7/10/2018	34	0.079	86.3%	0.1200	594.1	7520.1
1	2018	7/10/2018	35	0.08	88.3%	0.1200	615.9	7699
1	2018	7/10/2018	36	0.085	88.6%	0.1200	656.3	7721.5
1	2018	7/10/2018	37	0.096	91.3%	0.1200	764.2	7960.7
1	2018	7/10/2018	38	0.091	90.9%	0.1200	720.9	7921.8
1	2018	7/10/2018	39	0.074	91.1%	0.1200	587.6	7940
1	2018	7/10/2018	40	0.079	91.1%	0.1200	627.7	7945




2	2018	7/2/2018	0	0.073	99.6%	0.1200	634.1	8685.8
	2018	7/2/2018	1	0.07	98.9%	0.1200	603.6	8622.6
	2018	7/2/2018	2	0.066	93.4%	0.1200	537.5	8144.5
	2018	7/2/2018	3	0.098	77.3%	0.1200	660.2	6737.1
	2018	7/2/2018	4	0.056	0.6%	0.1200	3.06	54.6
	2018	7/2/2018	5			0.1200		
	2018	7/2/2018	6			0.1200		
	2018	7/2/2018	7			0.1200		
	2018	7/2/2018	8	0.031	2.7%	0.1200	7.344	236.232
	2018	7/2/2018	9	0.054	5.9%	0.1200	27.6	510.4
	2018	7/2/2018	10	0.156	7.6%	0.1200	103.3	662.3
	2018	7/2/2018	11	0.204	8.3%	0.1200	147.9	725
	2018	7/2/2018	12	0.44	16.4%	0.1200	627.8	1426.9
	2018	7/2/2018	13	0.385	25.0%	0.1200	837.5	2175.4
	2018	7/2/2018	14	0.309	36.8%	0.1200	991.4	3208.5
	2018	7/2/2018	15	0.316	54.2%	0.1200	1492	4721.4
	2018	7/2/2018	16	0.354	66.9%	0.1200	2063.9	5830.3
	2018	7/2/2018	17	0.351	66.6%	0.1200	2036.2	5801.3
	2018	7/2/2018	18	0.352	66.8%	0.1200	2048.5	5819.6
	2018	7/2/2018	19	0.344	68.7%	0.1200	2060.7	5990.5
	2018	7/3/2018	20	0.137	87.9%	0.1200	1049.5	7660.4
	2018	7/3/2018	21	0.092	96.1%	0.1200	771	8380.7
	2018	7/3/2018	22	0.092	97.9%	0.1200	784.9	8531.9
	2018	7/3/2018	23	0.078	98.9%	0.1200	672.2	8618.4



		hr	lb/mmbtu	% Capacity	limit			
2	2018	7/9/2018	0	0.071	77.7%	0.1200	480.8	6772.3
	2018	7/9/2018	1	0.072	78.0%	0.1200	489.3	6795.5
	2018	7/9/2018	2	0.069	77.8%	0.1200	467.9	6781.8
	2018	7/9/2018	3	0.071	78.2%	0.1200	483.8	6814.8
	2018	7/9/2018	4	0.075	78.0%	0.1200	509.9	6798.6
	2018	7/9/2018	5	0.083	78.4%	0.1200	567.5	6837.1
	2018	7/9/2018	6	0.067	78.1%	0.1200	456.4	6811.5
	2018	7/9/2018	7	0.07	78.9%	0.1200	481.3	6876.3
	2018	7/9/2018	8	0.073	78.2%	0.1200	497.4	6814.1
	2018	7/9/2018	9	0.27	59.1%	0.1200	1391.4	5153.3
	2018	7/9/2018	10	0.259	69.6%	0.1200	1571.6	6067.9
	2018	7/9/2018	11	0.067	79.3%	0.1200	463	6910.6
	2018	7/9/2018	12	0.076	85.8%	0.1200	568.5	7480.9
	2018	7/9/2018	13	0.07	87.8%	0.1200	535.7	7652.7
	2018	7/9/2018	14	0.064	86.8%	0.1200	484.4	7568.2
	2018	7/9/2018	15	0.066	86.9%	0.1200	500	7576.3
	2018	7/9/2018	16	0.07	87.6%	0.1200	534.3	7633.2
	2018	7/9/2018	17	0.073	87.2%	0.1200	554.9	7600.9
	2018	7/9/2018	18	0.073	87.6%	0.1200	557.4	7636.1
	2018	7/9/2018	19	0.074	87.8%	0.1200	566.2	7650.8
	2018	7/9/2018	20	0.083	87.5%	0.1200	633.4	7630.8
	2018	7/9/2018	21	0.08	76.6%	0.1200	534	6674.4
	2018	7/9/2018	22	0.398	63.4%	0.1200	2199.3	5525.8
	2018	7/9/2018	23	0.375	64.1%	0.1200	2094.7	5585.8
	2018	7/10/2018	24	0.343	65.2%	0.1200	1948.1	5679.7
	2018	7/10/2018	25	0.149	78.9%	0.1200	1025	6879.5
	2018	7/10/2018	26	0.068	79.8%	0.1200	472.8	6952.7
	2018	7/10/2018	27	0.072	87.7%	0.1200	550.6	7647.2
	2018	7/10/2018	28	0.067	87.2%	0.1200	509.3	7600.8
	2018	7/10/2018	29	0.066	86.4%	0.1200	496.9	7528.8
	2018	7/10/2018	30	0.067	85.9%	0.1200	501.4	7484
	2018	7/10/2018	31	0.071	89.3%	0.1200	552.7	7784.3
	2018	7/10/2018	32	0.071	92.2%	0.1200	570.7	8037.4




		lb/mmbtu	% Capacity	limit			
2017	8/16/2017	0	0.209	11.8%	0.1200	194.3	931.3
2017	8/16/2017	1	0.258	16.7%	0.1200	341	1321.5
2017	8/16/2017	2	0.332	22.4%	0.1200	588.4	1773.5
2017	8/16/2017	3	0.337	26.5%	0.1200	707	2096.4
2017	8/16/2017	4	0.329	28.1%	0.1200	731.1	2223.8
2017	8/16/2017	5	0.315	29.7%	0.1200	740	2346.9
2017	8/16/2017	6	0.322	29.1%	0.1200	740.1	2300.2
2017	8/16/2017	7	0.317	32.6%	0.1200	816.4	2576.1
2017	8/16/2017	8	0.282	39.1%	0.1200	873.7	3098.1
2017	8/16/2017	9	0.263	46.0%	0.1200	957.9	3644
2017	8/16/2017	10	0.201	50.8%	0.1200	809.3	4019.7
2017	8/16/2017	11	0.054	59.6%	0.1200	256.7	4713.3
2017	8/16/2017	12	0.055	64.8%	0.1200	284.3	5124.6
2017	8/16/2017	13	0.066	65.2%	0.1200	340.4	5159.4
2017	8/16/2017	14	0.049	63.5%	0.1200	246	5024.1
2017	8/16/2017	15	0.051	57.8%	0.1200	235.6	4577.4
2017	8/16/2017	16	0.055	58.0%	0.1200	254.5	4587.8
2017	8/16/2017	17	0.057	58.0%	0.1200	263.7	4588.1
2017	8/16/2017	18	0.057	57.6%	0.1200	262.1	4560.3
2017	8/16/2017	19	0.058	57.7%	0.1200	266.8	4562.5
2017	8/16/2017	20	0.057	57.5%	0.1200	261.4	4547.3
2017	8/16/2017	21	0.057	57.4%	0.1200	260.9	4539.8
2017	8/16/2017	22	0.056	57.6%	0.1200	255.1	4559.5
2017	8/16/2017	23	0.06	57.9%	0.1200	277	4580.7




bm


hr	lb/mmbtu	% Capacity	limit		
2017 9/25/2017	3	0.015	3.3%	0.1200	3.88 258.408
2017 9/25/2017	4	0.09	6.7%	0.1200	48 533.4
2017 9/25/2017	5	0.132	8.5%	0.1200	89.4 675
2017 9/25/2017	6	0.156	9.9%	0.1200	121.9 781.3
2017 9/25/2017	7	0.198	11.4%	0.1200	178.3 899.8
2017 9/25/2017	8	0.263	15.7%	0.1200	326.4 1241.1
2017 9/25/2017	9	0.27	16.6%	0.1200	356 1316.1
2017 9/25/2017	10	0.284	17.3%	0.1200	388.7 1368.9
2017 9/25/2017	11	0.329	20.8%	0.1200	541.4 1645.9
2017 9/25/2017	12	0.336	26.0%	0.1200	691.3 2055.7
2017 9/25/2017	13	0.34	25.7%	0.1200	689.8 2030.2
2017 9/25/2017	14	0.271	37.1%	0.1200	795.8 2935.3
2017 9/25/2017	15	0.271	40.8%	0.1200	875.9 3231
2017 9/25/2017	16	0.275	42.1%	0.1200	914.4 3330.4
2017 9/25/2017	17	0.155	45.3%	0.1200	557.7 3586.6
2017 9/25/2017	18	0.052	54.4%	0.1200	225.8 4304.1
2017 9/25/2017	19	0.05	58.5%	0.1200	231.4 4630.7
2017 9/25/2017	20	0.087	61.0%	0.1200	419.6 4827.5
2017 9/25/2017	21	0.081	69.6%	0.1200	448.7 5512
2017 9/25/2017	22	0.071	79.0%	0.1200	447 6255.9
2017 9/25/2017	23	0.067	79.0%	0.1200	418.8 6255.1



hc		hr	lb/mmbtu	% Capacity	limit		
	2018	6/17/2018	0	0.165	25.1%	0.1200	300.6 1822
	2018	6/17/2018	1	0.158	27.9%	0.1200	320.2 2026.5
	2018	6/17/2018	2	0.186	34.1%	0.1200	459.9 2472.4
	2018	6/17/2018	3	0.211	33.3%	0.1200	509.4 2414.4
	2018	6/17/2018	4	0.235	35.2%	0.1200	599.8 2552.5
	2018	6/17/2018	5	0.275	43.2%	0.1200	863.1 3138.4
	2018	6/17/2018	6	0.156	47.9%	0.1200	542.1 3475.1
	2018	6/17/2018	7	0.119	48.5%	0.1200	418.8 3519
	2018	6/17/2018	8	0.114	48.4%	0.1200	400.4 3512.1
	2018	6/17/2018	9	0.104	49.2%	0.1200	371.4 3571.5
	2018	6/17/2018	10	0.097	49.0%	0.1200	345.3 3559.6
	2018	6/17/2018	11	0.116	49.4%	0.1200	415.9 3585.1
	2018	6/17/2018	12	0.105	49.4%	0.1200	376.4 3584.9
	2018	6/17/2018	13	0.113	51.7%	0.1200	424.2 3753.9
	2018	6/17/2018	14	0.108	55.6%	0.1200	435.7 4034
	2018	6/17/2018	15	0.105	71.9%	0.1200	548.3 5221.5
	2018	6/17/2018	16	0.104	74.4%	0.1200	561.4 5398.2
	2018	6/17/2018	17	0.11	71.8%	0.1200	573.6 5214.8
	2018	6/17/2018	18	0.1	71.0%	0.1200	515.7 5156.5
	2018	6/17/2018	19	0.116	66.5%	0.1200	560.4 4831.1
	2018	6/17/2018	20	0.1	74.2%	0.1200	539 5390.1
	2018	6/17/2018	21	0.105	70.2%	0.1200	535.5 5100
	2018	6/17/2018	22	0.115	69.1%	0.1200	577 5017
	2018	6/17/2018	23	0.1	74.2%	0.1200	538.8 5387.5




c1	hr	lb/mmbtu	% Capacity	limit			
	2017 7/31/2017	0	0.081	108.1%	0.1200	705.6	8711.4
	2017 7/31/2017	1	0.081	108.2%	0.1200	706.5	8722.7
	2017 7/31/2017	2	0.08	108.1%	0.1200	697.2	8714.7
	2017 7/31/2017	3	0.209	53.2%	0.1200	895.9	4286.6
	2017 7/31/2017	4	0.279	57.1%	0.1200	1284.6	4604.3
	2017 7/31/2017	5	0.282	55.8%	0.1200	1268.5	4498.2
	2017 7/31/2017	6	0.283	55.0%	0.1200	1253.7	4430.1
	2017 7/31/2017	7	0.289	55.1%	0.1200	1283.8	4442.3
	2017 7/31/2017	8	0.298	55.8%	0.1200	1339.2	4494.1
	2017 8/1/2017	9	0.299	55.8%	0.1200	1344.7	4497.3
	2017 8/1/2017	10	0.151	56.8%	0.1200	691.3	4578.2
	2017 8/1/2017	11	0.078	56.3%	0.1200	353.7	4534.3
	2017 8/1/2017	12	0.078	56.4%	0.1200	354.5	4545.2
	2017 8/1/2017	13	0.077	56.2%	0.1200	348.7	4528
	2017 8/1/2017	14	0.078	56.6%	0.1200	355.7	4560.3
	2017 8/1/2017	15	0.075	64.2%	0.1200	388.2	5175.9
	2017 8/1/2017	16	0.079	103.9%	0.1200	661.6	8374.2
	2017 8/1/2017	17	0.081	108.9%	0.1200	710.8	8775.4




c2

hr		lb/mmbtu	% Capacity	limit			
2017	6/11/2017	0	0.024	5.6%	0.1200	10.8	451.9
2017	6/11/2017	1	0.109	8.2%	0.1200	72.4	663.8
2017	6/11/2017	2	0.198	9.3%	0.1200	148.3	749.1
2017	6/11/2017	3	0.198	10.3%	0.1200	163.9	827.6
2017	6/11/2017	4	0.198	9.5%	0.1200	151.5	764.9
2017	6/11/2017	5	0.206	8.9%	0.1200	147.3	715.2
2017	6/11/2017	6	0.226	9.6%	0.1200	174.5	772
2017	6/11/2017	7	0.275	12.2%	0.1200	270.4	983.4
2017	6/11/2017	8	0.271	27.6%	0.1200	601.9	2221.2
2017	6/11/2017	9	0.225	56.1%	0.1200	1016.8	4518.9
2017	6/11/2017	10	0.237	71.3%	0.1200	1362.3	5747.9
2017	6/11/2017	11	0.241	72.8%	0.1200	1413.4	5864.7
2017	6/11/2017	12	0.246	74.2%	0.1200	1470.2	5976.6
2017	6/11/2017	13	0.291	65.6%	0.1200	1538.9	5288.2
2017	6/11/2017	14	0.296	75.9%	0.1200	1812	6121.5
2017	6/11/2017	15	0.286	94.6%	0.1200	2179.5	7620.8
2017	6/11/2017	16	0.288	99.2%	0.1200	2302.4	7994.5
2017	6/11/2017	17	0.085	116.4%	0.1200	797.6	9383.3
2017	6/11/2017	18	0.07	109.6%	0.1200	618.2	8831.7
2017	6/11/2017	19	0.07	109.7%	0.1200	619.2	8845.1
2017	6/11/2017	20	0.07	114.6%	0.1200	646.7	9238.9



c1	hr	lb/mmbtu	% Capacity	limit		
	2018 5/1/2018	0	0.029	5.2%	0.1200	12.152 418.264
	2018 5/1/2018	1	0.022	4.5%	0.1200	8 365.8
	2018 5/1/2018	2	0.039	6.1%	0.1200	19.3 495.1
	2018 5/1/2018	3	0.063	8.2%	0.1200	41.6 660.4
	2018 5/1/2018	4	0.08	8.6%	0.1200	55.7 696.6
	2018 5/1/2018	5	0.083	7.4%	0.1200	49.7 598.2
	2018 5/1/2018	6	0.133	7.0%	0.1200	74.9 562.8
	2018 5/1/2018	7	0.237	8.4%	0.1200	159.9 674.7
	2018 5/1/2018	8	0.238	8.6%	0.1200	165.8 696.7
	2018 5/1/2018	9	0.264	12.0%	0.1200	254.8 965.2
	2018 5/1/2018	10	0.265	25.6%	0.1200	547.3 2065.4
	2018 5/1/2018	11	0.237	43.6%	0.1200	832.6 3512.9
	2018 5/2/2018	12	0.26	53.9%	0.1200	1130.4 4347.6
	2018 5/2/2018	13	0.306	59.9%	0.1200	1476.9 4826.6
	2018 5/2/2018	14	0.28	63.4%	0.1200	1430.3 5108.1
	2018 5/2/2018	15	0.287	71.2%	0.1200	1645.9 5734.8
	2018 5/2/2018	16	0.258	71.4%	0.1200	1483.7 5750.9
	2018 5/2/2018	17	0.094	70.9%	0.1200	536.9 5711.9
	2018 5/2/2018	18	0.078	71.1%	0.1200	447.2 5733.6
	2018 5/2/2018	19	0.082	71.9%	0.1200	474.9 5791.7
	2018 5/2/2018	20	0.08	80.4%	0.1200	518.7 6483.7
	2018 5/2/2018	21	0.078	86.3%	0.1200	542.3 6952.1
	2018 5/2/2018	22	0.079	86.1%	0.1200	548.2 6939.3



c1	hr	lb/mmbtu	% Capacity	limit		
	2018 6/29/2018	0	0.075	3.1%	0.1200	18.48 246.36
	2018 6/29/2018	1	0.051	7.3%	0.1200	30.1 590.6
	2018 6/29/2018	2	0.175	9.7%	0.1200	136.2 778.5
	2018 6/29/2018	3	0.248	11.7%	0.1200	233.4 941
	2018 6/29/2018	4	0.306	17.9%	0.1200	440.8 1440.5
	2018 6/29/2018	5	0.27	37.5%	0.1200	815.5 3020.5
	2018 6/29/2018	6	0.248	64.1%	0.1200	1280.6 5163.9
	2018 6/29/2018	7	0.305	66.7%	0.1200	1639.9 5376.8
	2018 6/30/2018	8	0.279	75.2%	0.1200	1690.1 6057.6
	2018 6/30/2018	9	0.27	76.0%	0.1200	1653.2 6122.9
	2018 6/30/2018	10	0.269	75.4%	0.1200	1635.7 6080.5
	2018 6/30/2018	11	0.267	74.7%	0.1200	1606.9 6018.5
	2018 6/30/2018	12	0.26	74.7%	0.1200	1566.1 6023.4
	2018 6/30/2018	13	0.264	67.8%	0.1200	1441.9 5461.9
	2018 6/30/2018	14	0.271	62.8%	0.1200	1371.1 5059.4
	2018 6/30/2018	15	0.287	83.3%	0.1200	1925.9 6710.4
	2018 6/30/2018	16	0.111	101.0%	0.1200	903.8 8142.2
	2018 6/30/2018	17	0.077	101.3%	0.1200	628.6 8163.8
	2018 6/30/2018	18	0.077	101.8%	0.1200	631.7 8204.3
	2018 6/30/2018	19	0.077	102.7%	0.1200	637.3 8276
	2018 6/30/2018	20	0.077	96.5%	0.1200	598.9 7778.4
	2018 6/30/2018	21	0.077	98.6%	0.1200	612.2 7950.4
	2018 6/30/2018	22	0.077	102.2%	0.1200	634.4 8239.4

